


ŘEZ B - B'

ČERPADLO SIGMA 50 GFRU-95-12-LC-102
 $Q = 7 \text{ l/s}$, $H = 6 \text{ m.v.s.l.}$, $P_n = 1,5 \text{ kW}$

ČERPADLO SIGMA 50 GFRU-95-12-LC-102
 $Q = 7 \text{ l/s}$, $H = 6 \text{ m.v.s.l.}$, $P_n = 1,5 \text{ kW}$

DMYCHADLO LUTOS DI-20T-4
 $Q = 16,7 \text{ m}^3/\text{h}$, $\Delta p = 50 \text{ kPa}$, $P_n = 4 \text{ kW}$, 2900 ot/min.

STROJNÍ ČESLE EKOPROGRES
 $B = 400 \text{ mm}$, $P_n = 0,37 \text{ kW}$



ŘEZ C-C'

STROJNÍ ČESLE EKOPROGRES

B=400mm, $P_H=0,37kW$

KOMPRESOROVÁ STANICE ORLÍK 2 JVK 50

$Q=9m^3/h$, $p=800kPa$, $P_H=1,5kW$

STROJNÍ ČESLE EKOPROGRES

B=400mm, $P_H=0,37kW$

